


**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: Edgemont Schools - Greenville School

Date Collected: 04/21/2021  
 Collected By: Nicholas Coon  
 Date Received: 04/21/2021  
 Date Analyzed: 04/27/2021  
 Analyzed By: Ernest Sanchez  
 Signature:   
 Analyte: Pb Water  
 Analytical Method: EPA 200.9  
 NYS Lab Number: 10851

Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2753808	Boys Bathroom by A1 - Sink #2	Water	BDL < 0.001 mg/L
2 2753809	Girls Bathroom by A1 - Sink #2	Water	0.001 mg/L
3 2753810	Small Office Between A1 and A3 - Sink	Water	0.002 mg/L
4 2753811	Classroom A6 - Sink	Water	BDL < 0.001 mg/L
5 2753812	Classroom A5 - Sink	Water	BDL < 0.001 mg/L
6 2753813	Classroom A8 - Sink	Water	0.009 mg/L
7 2753814	Classroom A7 - Sink	Water	BDL < 0.001 mg/L
8 2753815	Classroom A10 - Sink	Water	0.003 mg/L
9 2753816	Classroom A9 - Sink	Water	0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: Edgemont Schools - Greenville School

Date Collected: 04/21/2021  
 Collected By: Nicholas Coon  
 Date Received: 04/21/2021  
 Date Analyzed: 04/27/2021  
 Analyzed By: Ernest Sanchez  
 Signature:   
 Analyte: Pb Water  
 Analytical Method: EPA 200.9  
 NYS Lab Number: 10851

Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2753817	Classroom A12 - Sink	Water	0.001 mg/L
11 2753818	Classroom A11 - Sink	Water	0.001 mg/L
12 2753819	Classroom A11 - Bubbler	Water	0.027 mg/L
13 2753820	Gym Boys Bathroom - Sink	Water	0.001 mg/L
14 2753821	Gym Bathroom Outside A15 - Sink	Water	0.001 mg/L
15 2753822	Boys Bathroom Room 154 - Sink #2	Water	0.003 mg/L
16 2753823	Boys Bathroom Room 154 - Sink #3	Water	0.001 mg/L
17 2753824	Library Office - Sink	Water	BDL < 0.001 mg/L
18 2753825	Girls Bathroom Room 148 - Sink #1	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: Edgemont Schools - Greenville School

Date Collected: 04/21/2021  
 Collected By: Nicholas Coon  
 Date Received: 04/21/2021  
 Date Analyzed: 04/27/2021  
 Analyzed By: Ernest Sanchez  
 Signature:   
 Analyte: Pb Water  
 Analytical Method: EPA 200.9  
 NYS Lab Number: 10851

Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2753826	Girls Bathroom Room 148 - Sink #2	Water	BDL < 0.001 mg/L
20 2753827	Water Fountain by All Purpose Room - Bottle Filler	Water	BDL < 0.001 mg/L
21 2753828	Classrom C7 - Sink	Water	BDL < 0.001 mg/L
22 2753829	Classrom C10 - Sink	Water	BDL < 0.001 mg/L
23 2753830	Classrom C5 - Sink	Water	BDL < 0.001 mg/L
24 2753831	Classrom C8 - Sink	Water	BDL < 0.001 mg/L
25 2753832	Classrom C6 - Sink	Water	BDL < 0.001 mg/L
26 2753833	Classrom C3 - Sink	Water	0.005 mg/L
27 2753834	Classrom C1 - Sink	Water	0.017 mg/L

BDL = Below Detectable Limits  
 Liability Limited to Cost of Analysis  
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: Edgemont Schools - Greenville School

Date Collected: 04/21/2021  
 Collected By: Nicholas Coon  
 Date Received: 04/21/2021  
 Date Analyzed: 04/27/2021  
 Analyzed By: Ernest Sanchez  
 Signature:   
 Analyte: Pb Water  
 Analytical Method: EPA 200.9  
 NYS Lab Number: 10851

Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28 2753835	Kitchen by Cafeteria - Sink	Water	0.001 mg/L
29 2753836	Water Fountain by Boiler Room Door - Bottle Filler	Water	BDL < 0.001 mg/L
30 2753837	Faculty Room - Sink	Water	0.001 mg/L
31 2753838	Faculty Room - Sprayer Head	Water	0.003 mg/L
32 2753839	Classroom B1 - Sink	Water	0.001 mg/L
33 2753840	Classroom B3 - Sink	Water	0.001 mg/L
34 2753841	Bathroom Between B1 & B3 - Sink #2	Water	0.001 mg/L
35 2753842	Classrom B5 - Sink	Water	BDL < 0.001 mg/L
36 2753843	Classrom B7 - Sink	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: Edgemont Schools - Greenville School

Date Collected: 04/21/2021  
 Collected By: Nicholas Coon  
 Date Received: 04/21/2021  
 Date Analyzed: 04/27/2021  
 Analyzed By: Ernest Sanchez  
 Signature:   
 Analyte: Pb Water  
 Analytical Method: EPA 200.9  
 NYS Lab Number: 10851

Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
37 2753844	Bathroom Between B5 & B7 - Sink #2	Water	0.001 mg/L
38 2753845	Classrom B8 - Sink	Water	0.006 mg/L
HS1 2753846	Kitchen - Kettle Faucet Head	Water	BDL < 0.001 mg/L
HS2 2753847	Gym Boys Locker Room Bathroom - Sink #1	Water	BDL < 0.001 mg/L
HS3 2753848	Gym Girls Locker Room Bathroom - Sink #1	Water	0.001 mg/L
HS4 2753849	Gym Girls Locker Room Bathroom - Sink #2	Water	0.003 mg/L
HS5 2753850	Gym Girls Locker Room Bathroom - Sink #3	Water	0.006 mg/L
HS6 2753851	Outdoors by Tennis Courts - Water Fountain (Bubbler)	Water	0.003 mg/L
HS7 2753852	Outdoors by Tennis Courts - Spigot	Water	0.002 mg/L

BDL = Below Detectable Limits  
 Liability Limited to Cost of Analysis  
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

### Eastern Analytical Services, Inc. Water Sample Report

RE: Edgemont Schools - Greenville School

Date Collected: 04/21/2021  
Collected By: Nicholas Coon  
Date Received: 04/21/2021  
Date Analyzed: 04/27/2021  
Analyzed By: Ernest Sanchez  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
Blank 2753853	Not Applicable	Blank	BDL < 0.001 mg/L