


Eastern Analytical Services, Inc.
Water Sample Report

RE: Edgemont Schools - High/Middle School

Date Collected: 04/20/2021
 Collected By: Nicholas Coon
 Date Received: 04/20/2021
 Date Analyzed: 04/27/2021
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2753753	Boys Sink in Admin Building - Sink #2	Water	0.001 mg/L
2 2753754	Admin Building Girls Bathroom - Sink #1	Water	0.001 mg/L
3 2753755	Nurses Office - Fridge Water Dispenser	Water	BDL < 0.001 mg/L
4A&4B 2753756	Nurses Office - Fridge Ice Machine	Water	BDL < 0.001 mg/L
5 2753757	Teachers Lounge - Sink	Water	BDL < 0.001 mg/L
6 2753758	Kitchen - Sink #1	Water	0.003 mg/L
7 2753759	Kitchen - Sink #2	Water	0.001 mg/L
8 2753760	Kitchen - Sink #3	Water	0.003 mg/L
9 2753761	Kitchen - Sink #4	Water	0.037 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Edgemont Schools - High/Middle School

Date Collected: 04/20/2021
 Collected By: Nicholas Coon
 Date Received: 04/20/2021
 Date Analyzed: 04/27/2021
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2753762	Cafeteria - Water Fountain (Bottle Filler)	Water	0.001 mg/L
11 2753763	Building D 1st Floor - Water Fountain (Elkay) (Bottle Filler)	Water	BDL < 0.001 mg/L
12 2753764	Building D 2nd Floor - WaterFountain (Bottle Filler)	Water	BDL < 0.001 mg/L
13 2753765	Building D Chemistry Prep Room - Sink	Water	0.012 mg/L
14 2753766	AV Room Offices - Sink	Water	0.003 mg/L
15 2753767	Building E 1st Floor Boys Bathroom - Sink #2	Water	0.001 mg/L
16 2753768	Building E 1st Floor Boys Bathroom - Sink #3	Water	BDL < 0.001 mg/L
17 2753769	Building E 1st Floor Girls Bathroom - Sink #1	Water	BDL < 0.001 mg/L
18 2753770	Building E 1st Floor - Left Side Water Fountain (Bubbler)	Water	0.004 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Edgemont Schools - High/Middle School

Date Collected: 04/20/2021
 Collected By: Nicholas Coon
 Date Received: 04/20/2021
 Date Analyzed: 04/27/2021
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2753771	Building E 1st Floor - Right Side Water Fountain (Bubbler)	Water	BDL < 0.001 mg/L
20 2753772	Library - Water Fountain (Bottle Filler)	Water	BDL < 0.001 mg/L
21 2753773	Library Office - Sink	Water	0.003 mg/L
22 2753774	Building E 2nd Floor - Water Fountain #1 (Bubbler)	Water	BDL < 0.001 mg/L
23 2753775	Building E 2nd Floor - Water Fountain #2 (Bubbler)	Water	BDL < 0.001 mg/L
24 2753776	Building E "A" School Room 112 - Sink	Water	BDL < 0.001 mg/L
25 2753777	Building A 1st Floor Boys Bathroom - Sink #2	Water	BDL < 0.001 mg/L
26 2753778	Building A 1st Floor Boys Bathroom - Sink #3	Water	0.009 mg/L
27 2753779	Building A 1st Floor Girls Bathroom - Sink #2	Water	0.002 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Edgemont Schools - High/Middle School

Date Collected: 04/20/2021
 Collected By: Nicholas Coon
 Date Received: 04/20/2021
 Date Analyzed: 04/27/2021
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28 2753780	Building A 1st Floor Girls Bathroom - Sink #3	Water	BDL < 0.001 mg/L
29 2753781	Building A 1st Floor - Water Fountain (Bubbler)	Water	0.006 mg/L
30 2753782	Building A 1st Floor - Water Fountain (Bubbler)	Water	0.003 mg/L
31 2753783	Building B 1st Floor by B7 - Water Fountain (Bubbler)	Water	0.001 mg/L
32 2753784	Building B 1st Floor Girls Bathroom - Sink #2	Water	BDL < 0.001 mg/L
33 2753785	Building B Room B2 Prep Room - Sink	Water	0.008 mg/L
34 2753786	Building B Boys Bathroom 1st Floor - Sink #1	Water	BDL < 0.001 mg/L
35 2753787	Building C Womens Bathroom - Sink #1	Water	0.003 mg/L
36 2753788	Building C Hallway - Water Fountain (Bubbler)	Water	0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Edgemont Schools - High/Middle School

Date Collected: 04/20/2021
 Collected By: Nicholas Coon
 Date Received: 04/20/2021
 Date Analyzed: 04/27/2021
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
37 2753789	Building C Boys Bathroom - Sink #2	Water	0.003 mg/L
38 2753790	C1 Prep Room - Sink	Water	0.005 mg/L
39A&39B 2753791	Kitchen - Ice Machine	Water	BDL < 0.001 mg/L
40A&40B 2753792	Gym Concessions Room - Ice Machine	Water	BDL < 0.001 mg/L
41 2753793	Gym Concessions Room - Sink	Water	BDL < 0.001 mg/L
42 2753794	Gym Hallway - Water Fountain (Bottle Filler)	Water	BDL < 0.001 mg/L
43 2753795	Gym Womens Bathroom by Hallway - Sink #2	Water	0.001 mg/L
44 2753796	Gym Hallway by Mens Bathroom - Water Fountain (Bubbler)	Water	BDL < 0.001 mg/L
45 2753797	Gym Mens Bathroom by Hallway - Sink #1	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Edgemont Schools - High/Middle School

Date Collected: 04/20/2021
 Collected By: Nicholas Coon
 Date Received: 04/20/2021
 Date Analyzed: 04/27/2021
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
46 2753798	Boys Locker Room - Water Fountain (Bubbler)	Water	BDL < 0.001 mg/L
47 2753799	Girls Locker Room - Water Fountain (Bubbler)	Water	BDL < 0.001 mg/L
48 2753800	Facilities Directors Office - Sink	Water	0.006 mg/L
49 2753801	Outdoor Field - Water Fountain (Bubbler)	Water	BDL < 0.001 mg/L
50 2753802	Outdoor Field - Bottle Filler	Water	BDL < 0.001 mg/L
51 2753803	Field Box Far Side - Spigot #1	Water	BDL < 0.001 mg/L
52 2753804	Field Box Far Side - Spigot #2	Water	0.006 mg/L
53 2753805	Field Box Bleacher Side - Spigot #3	Water	BDL < 0.001 mg/L
54 2753806	Field Box Bleacher Side - Spigot #4	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

Water Sample Report

RE: Edgemont Schools - High/Middle School

Date Collected: 04/20/2021
Collected By: Nicholas Coon
Date Received: 04/20/2021
Date Analyzed: 04/27/2021
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
Blank 2753807	Not Applicable	Blank	BDL < 0.001 mg/L