



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779  
T: 631.580.3191 • F: 631.580.3195 • W: [envirohealth.org](http://envirohealth.org)

January 18, 2023

Mr. Ray Renda  
Edgemont UFSD  
300 White Oak Lane  
Scarsdale, NY 10583

Re: **Lead in Drinking Water Sampling & Analysis 2023-2025**

Dear Mr. Renda,

On January 12, 2023, EnviroScience Consultants performed a limited water sampling event at the Edgemont Union Free School District. One sample was collected at the Edgemont Jr/Sr High School.

A first draw sample was collected in wide-mouth 250 milliliter container and during the early morning, prior to any water sources being used. The sample was transported to New York Environmental Laboratory and analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb).

The following location was above the limit:

Resource Building A/V sink: 104 ppb

The sink is not used as a source for drinking water and was determined to be a non-applicable location. A permanent sign is posted.

Please see the attached lab report for results. This location has satisfied the requirement for the 2023-2025 Lead in Drinking Water sampling period.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Susan Richter".

Susan Richter

## Laboratory Report

NYE Report #: 230061-23879

January 13, 2023

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Edgemont JR/SR High School; 200 White Oak Lane Scarsdale, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 12, 2023. New York Environmental analyzed the samples on January 13, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	12 Jan 2023
Date Received:	12 Jan 2023
Date Analyzed:	13 Jan 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
230112K001	1	Resource Bldg A/V Sink-SK; Initial	0.001	0.104	mg/L	E,H

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.