


**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN EDG-1035-16-IH - Edgemont UFSD - Seely School

Date Collected: 04/01/2016  
 Collected By: Ernest Coon  
 Date Received: 04/01/2016  
 Date Analyzed: 04/08/2016  
 Analyzed By: Peter P. Argyrakis  
 Signature:   
 Analyte: Pb Water  
 Analytical Method EPA 200.9  
 NYS Lab Number: 10851


Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2417666	Main Floor - Classroom 106 Sink	Water	0.008 mg/L
1B 2417667	Main Floor - Classroom 106 Sink	Water	0.004 mg/L
2A 2417668	Main Floor - Kindergarten Room 101 Water Fountain	Water	0.001 mg/L
2B 2417669	Main Floor - Kindergarten Room 101 Water Fountain	Water	0.001 mg/L
3A 2417670	Main Floor - Kindergarten Room 101 - Sink Next to Water Fountain	Water	0.011 mg/L
3B 2417671	Main Floor - Kindergarten Room 101 - Sink Next to Water Fountain	Water	0.001 mg/L
4A 2417672	Hallway Water Fountain - Next to Room 104	Water	0.010 mg/L
4B 2417673	Hallway Water Fountain - Next to Room 104	Water	0.002 mg/L
5A 2417674	Hallway Water Fountain - Next to Room 110	Water	0.008 mg/L

BDL = Below Detectable Limits  
 Liability Limited to Cost of Analysis  
 Results Applicable to Those Items Tested

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN EDG-1035-16-IH - Edgemont UFSD - Seely School

Date Collected: 04/01/2016  
 Collected By: Ernest Coon  
 Date Received: 04/01/2016  
 Date Analyzed: 04/08/2016  
 Analyzed By: Peter P. Argyrakis  
 Signature:   
 Analyte: Pb Water  
 Analytical Method EPA 200.9  
 NYS Lab Number: 10851


Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
5B 2417675	Hallway Water Fountain - Next to Room 110	Water	0.003 mg/L
6A 2417676	Classroom 110 Sink	Water	0.023 mg/L
6B 2417677	Classroom 110 Sink	Water	0.002 mg/L
7A 2417678	Hallway Water Fountain by APR	Water	BDL < 0.001 mg/L
7B 2417679	Hallway Water Fountain by APR	Water	BDL < 0.001 mg/L
8A 2417680	Classroom 113 Sink (ETA Associates Office)	Water	0.020 mg/L
8B 2417681	Classroom 113 Sink (ETA Associates Office)	Water	0.001 mg/L
9A 2417682	Faculty Lounge (Room 215) Sink	Water	0.001 mg/L
9B 2417683	Faculty Lounge (Room 215) Sink	Water	0.001 mg/L

BDL = Below Detectable Limits  
 Liability Limited to Cost of Analysis  
 Results Applicable to Those Items Tested

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN EDG-1035-16-IH - Edgemont UFSD - Seely School

Date Collected: 04/01/2016  
 Collected By: Ernest Coon  
 Date Received: 04/01/2016  
 Date Analyzed: 04/08/2016  
 Analyzed By: Peter P. Argyrakis  
 Signature:   
 Analyte: Pb Water  
 Analytical Method EPA 200.9  
 NYS Lab Number: 10851


Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10A 2417684	Room 220A Sink	Water	0.381 mg/L
10B 2417685	Room 220A Sink	Water	0.204 mg/L
11A 2417686	Hallway Water Fountain Near Room 203	Water	0.003 mg/L
11B 2417687	Hallway Water Fountain Near Room 203	Water	0.002 mg/L
12A 2417688	Cafeteria Lunchroom Water Fountain (EL Key)	Water	0.001 mg/L
12B 2417689	Cafeteria Lunchroom Water Fountain (EL Key)	Water	BDL < 0.001 mg/L
13A 2417690	Cafeteria Lunchroom Water Fountain (Metcalf)	Water	0.010 mg/L
13B 2417691	Cafeteria Lunchroom Water Fountain (Metcalf)	Water	0.006 mg/L
14A 2417692	Cafeteria Lunchroom Sink	Water	0.002 mg/L

BDL = Below Detectable Limits  
 Liability Limited to Cost of Analysis  
 Results Applicable to Those Items Tested

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN EDG-1035-16-IH - Edgemont UFSD - Seely School

Date Collected: 04/01/2016  
Collected By: Ernest Coon  
Date Received: 04/01/2016  
Date Analyzed: 04/08/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
14B 2417693	Cafeteria Lunchroom Sink	Water	0.002 mg/L
15A 2417694	Room 202 Sink	Water	0.033 mg/L
15B 2417695	Room 202 Sink	Water	0.057 mg/L
16A 2417696	Hallway Water Fountain Near Gym	Water	0.010 mg/L
16B 2417697	Hallway Water Fountain Near Gym	Water	0.003 mg/L
17A 2417698	Art Room 006 (Next to Windows)	Water	0.025 mg/L
17B 2417699	Art Room 006 (Next to Windows)	Water	0.001 mg/L
18A 2417700	Art Room 006 (Next to Windows)	Water	0.018 mg/L
18B 2417701	Art Room 006 (Next to Windows)	Water	0.001 mg/L

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN EDG-1035-16-IH - Edgemont UFSD - Seely School

Date Collected: 04/01/2016

Collected By: Ernest Coon

Date Received: 04/01/2016

Date Analyzed: 04/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2417702	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095