


**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN EDGE-1049-16-IH - Edgemont UFSD - HS/MS - Seely Place - Greenville  
Elementary


Date Collected: 04/28/2016  
Collected By: Ernest Coon  
Date Received: 04/28/2016  
Date Analyzed: 05/02/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2422519	HS/MS Resources Building - AV Sink	Water	0.004 mg/L
1B 2422520	HS/MS Resources Building - AV Sink	Water	BDL < 0.001 mg/L
2A 2422521	HS/MS Resources Building - Library Office Sink	Water	0.004 mg/L
2B 2422522	HS/MS Resources Building - Library Office Sink	Water	BDL < 0.001 mg/L
3A 2422523	HS/MS C-1 Office behind Classroom	Water	0.016 mg/L
3B 2422524	HS/MS C-1 Office behind Classroom	Water	BDL < 0.001 mg/L
4A 2422525	Seely Nurse's Office Sink	Water	0.003 mg/L
4B 2422526	Seely Nurse's Office Sink	Water	BDL < 0.001 mg/L
5A 2422527	Greenville Middle Wing Water Fountain	Water	BDL < 0.001 mg/L

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN EDGE-1049-16-IH - Edgemont UFSD - HS/MS - Seely Place - Greenville  
Elementary

Date Collected: 04/28/2016  
Collected By: Ernest Coon  
Date Received: 04/28/2016  
Date Analyzed: 05/02/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
5B 2422528	Greenville Middle Wing Water Fountain	Water	0.004 mg/L
6A 2422529	Nurse's Office Sink	Water	0.003 mg/L
6B 2422530	Nurse's Office Sink	Water	BDL < 0.001 mg/L
7 2422531	Not Applicable	Water Blank	BDL < 0.001 mg/L