


**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN Edge-1088-16-IH

Date Collected: 07/20/2016  
Collected By: Nicholas Coon  
Date Received: 07/20/2016  
Date Analyzed: 07/27/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2439126	Gym Sink in Concession Area	Water	0.001 mg/L
1B 2439127	Gym Sink in Concession Area	Water	BDL < 0.001 mg/L
2A 2439128	Gym Fountain by Football Locker Room	Water	0.001 mg/L
2B 2439129	Gym Fountain by Football Locker Room	Water	BDL < 0.001 mg/L
Blank 2439130	Not Applicable	Water Blank	BDL < 0.001 mg/L