


Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN EDG-1142-16-IH - Edgemont UFSD - High School - Seely - Greenville

Date Collected: 10/25/2016
Collected By: S. Coon
Date Received: 10/25/2016
Date Analyzed: 11/03/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851


Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2462854	E.H.S. - Water Spigot by Boiler Room	Water	0.003 mg/L
2 2462855	E.H.S. - Water Spigot by Breezeway Towards "D" Building	Water	0.011 mg/L
3 2462856	E.H.S. - Water Spigot by Breezeway Towards "C" Building	Water	0.011 mg/L
4 2462857	E.H.S. - Water Spigot by "C" Building Garden	Water	0.002 mg/L
5 2462858	E.H.S. - Water Spigot by Front of "C" Building	Water	0.009 mg/L
6 2462859	E.H.S. - Water Spigot by Front of "A" Building	Water	0.009 mg/L
7 2462860	E.H.S. - Water Spigot by Front of "B" Building	Water	0.005 mg/L
8 2462861	E.H.S. - Water Spigot by Rear of "B" Building	Water	0.084 mg/L
9 2462862	E.H.S. - Water Spigot by Mech/HVAC Units	Water	0.038 mg/L

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN EDG-1142-16-IH - Edgemont UFSD - High School - Seely - Greenville

Date Collected: 10/25/2016
Collected By: S. Coon
Date Received: 10/25/2016
Date Analyzed: 11/03/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851


Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2462863	E.H.S. - Water Spigot Side of AV - Near "D" Building	Water	0.068 mg/L
11 2462864	E.H.S. - Water Spigot Rear of Business Office	Water	0.009 mg/L
12 2462865	E.H.S. - Water Spigot Front of Business Office	Water	0.007 mg/L
13 2462866	E.H.S. - Water Spigot - Side of Gym - Business Parking Lot	Water	0.032 mg/L
14 2462867	E.H.S. - Water Spigot - Maintenance Garage - Inside	Water	0.001 mg/L
15 2462868	E.H.S. - Water Spigot by Directors Office	Water	0.078 mg/L
16 2462869	E.H.S. - Water Spigot by Gym East - Near Directors Office	Water	0.022 mg/L
17 2462870	E.H.S. - Concession Ice Machine - 3 Samples to be Combined	Water	0.002 mg/L
18 2462871	E.H.S. - Water Spigot Side of Gym - Football Room	Water	0.051 mg/L

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN EDG-1142-16-IH - Edgemont UFSD - High School - Seely - Greenville

Date Collected: 10/25/2016
Collected By: S. Coon
Date Received: 10/25/2016
Date Analyzed: 11/03/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851


Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2462872	E.H.S. - Kitchen Ice Machine - 3 Samples to be Combined	Water	0.002 mg/L
20 2462873	E.H.S. - Field House Water Spigot	Water	0.011 mg/L
21 2462874	E.H.S. - Turf Field Spigot - South East Combo Box	Water	0.084 mg/L
22 2462875	E.H.S. - Turf Field Water Spigot - North East Combo Box	Water	0.107 mg/L
23 2462876	E.H.S. - Turf Field Water Spigot - North West Combo Box	Water	0.193 mg/L
24 2462877	E.H.S. - Turf Field Water Spigot - South West Combo Box	Water	1.114 mg/L
25 2462878	E.H.S. - Baseball Field Water Spigot	Water	0.066 mg/L
26 2462879	E.H.S. - Tennis Courts Water Spigot	Water	0.008 mg/L
27 2462880	Seely Place - Front of School - Ramp Water Spigot	Water	0.004 mg/L

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN EDG-1142-16-IH - Edgemont UFSD - High School - Seely - Greenville

Date Collected: 10/25/2016
Collected By: S. Coon
Date Received: 10/25/2016
Date Analyzed: 11/03/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28 2462881	Greenville - Water Spigot by Gas Meter	Water	0.016 mg/L
29 2462882	Greenville - Water Spigot #1 - Spigot Closest to Building/Inside - Serves Water Fountain	Water	0.093 mg/L
30 2462883	Greenville - Water Spigot #2 - Outside Spigot - Serves Lawn Sprinkler System	Water	0.084 mg/L
31 2462884	Greenville - Courtyard Between Classroom #1/2 Water Spigot	Water	0.795 mg/L
32 2462885	Greenville - Courtyard Water Spigot by Room #7	Water	0.048 mg/L
33 2462886	Not Applicable	Water Blank	0.001 mg/L
35 2462887	Greenville - Water Spigot in Garden by Room #108	Water	0.047 mg/L
36 2462888	Greenville - Water Spigot in Garden by Room #11	Water	0.243 mg/L