

# WATER QUALITY REPORTING

## EDGEMONT SCHOOL DISTRICT

- *EDGEMONT JUNIOR SENIOR HIGH SCHOOL*
- *SEELY PLACE ELEMENTARY SCHOOL*
- *GREENVILLE ELEMENTARY SCHOOL*

# NEW LEGISLATION

- *On September 06, 2016, Gov. Cuomo signed legislation requiring that school districts test their water for lead.*
- *Along with the signing of the legislation on September 06, 2016 – the NY State Department of Health issued emergency regulations pursuant to new legislation, requiring that school districts test their water for lead contamination by Oct. 31, 2016.*

# EDGEMONT TESTING

- *Water testing for all Edgemont Schools was completed on October, 26, 2016.*
- *Numerous sinks were previously tested in April 2016 with water in the piping that exceeded 18 hours of stagnation. All of these sinks were retested in September and October of 2016 with some testing below the action limit for lead content under the required protocol of 8-18 hours for standing water in piping.*
- *This notification tool is a living document and will be updated as needed.*
- *Please feel free to contact John McCabe, Director of Facilities, with any questions regarding this issue.*
  - *[jmccabe@edgemont.org](mailto:jmccabe@edgemont.org)*
  - *914 472-7767 X 4418*

# TEST RESULTS

*Edgemont Junior Senior High School*

See Posted Results

# **ELEVATED LEAD LEVELS**

*Edgemont Junior Senior High School*

See Posted Results

# REMEDIATION

## *Edgemont Junior Senior High School*

- *Replaced two faucets on a kitchen gang sink – fixtures retested under lead action limit*
- *Removed one kitchen sink*
- *Replaced sink faucet in room C-1 – fixture retested under lead action limit*
- *Display “Hand Washing Only” and “Not For Drinking” signage at sinks that are not suitable for consumption due to elevated lead levels*

# TEST RESULTS

*Greenville School*

See Posted Results

# ELEVATED LEAD LEVELS

## *Greenville School*

### Greenville School

<u>Sample #</u>	<u>Location</u>	<u>Lead Conc.</u>
39	CR 20 Sink	0.068
72	CR 107 Sink	0.035
74	CR 109 Sink	0.016
28-32	Outdoor Spigots	0.016-0.795
35-36	Outdoor Spigots	0.47-0.243



# REMEDIATION

## *Greenville School*

- *Resampled Middle Wing Fountain due to suspicious result – retest was under lead action limit*
- *Display “Hand Washing Only” and “Not For Drinking” signage at sinks that are not suitable for consumption due to elevated lead levels*

# TEST RESULTS

Seely School

See Posted Results

# ELEVATED LEVELS

## *Seely School*

### Seely Place School

<u>Sample</u>	<u>Location</u>	<u>Lead Conc.</u>
39	CR 104 Bathroom Sink	0.043
52	CR 112 Bathroom Sink	0.022
56	CR 220A Sink	0.025

# REMEDIATION

## Seely School

- *Display “Hand Washing Only” and “Not For Drinking” signage at sinks that are not suitable for consumption due to elevated lead levels*