

Lead Testing in School Drinking Water 2020 Compliance Requirements

In compliance with the NYS lead testing in school drinking water 2020 compliance requirements, Edgemont School District tested all fixtures throughout the district. Samples were taken from fixtures during April of 2021 and three fixtures came back positive for lead.

The positive results are listed below and have been sent to the Westchester County Department of Dept. of Health. All results from the recent round of testing will soon be available on the Edgemont website.

- 1) Edgemont Junior Senior HS - 200 White Oak Lane, Scarsdale, NY 10583
Kitchen faucet #4 - .037 mg/L
Posted signage that water is not potable
- 2) Greenville Elementary School - 100 Glendale Road, Scarsdale, NY 10583
Classroom A11 drinking fountain bubbler - 0.027 mg/L
Posted signage that water is not potable - shut off and removed fountain bubbler
- 3) Greenville Elementary School -100 Glendale Road, Scarsdale, NY 10583
Classroom C1 sink - 0.017 mg/L
Posted signage that water is not potable